

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 03-03-2026

It is certified that an inspection team headed by Dr. GANESH G SUVARNA from MEDICAL OFFICER and PHED inspected the THE SMART SCHOOL, 77/2, MACHOHALLI, BAPAGRAM POST, DASANAPURA HOBLI, BANGALORE -560091 on 02-03-2026 and on the basis of Water Test Report (Attached) bearing no. PHI/Water/BAC/1494/2025-26 dated 17-02-2026 and PHC Machohalli lab on 02-03-2026 certified that THE SMART SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State/Central Govt.

This certificate is valid till 02-03-2028

Signature With Seal

Name

: Dr. GANESH G SUVARNA

Designation

: Medical Officer

Name & Address of the Office / Department:

ವೈದ್ಯಾಧಿಕಾರಿಗಳು
ಪ್ರಾ.ಆ. ಕ್ರೀಂದ್ರ- ಮಾಚೋಹಳ್ಳಿ
ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ.

To

THE SMART SCHOOL, 77/2, MACHOHALLI,
BAPAGRAM POST, DASANAPURA HOBLI,
BANGALORE -560091

Report of Bacteriological analysis of Water Sample

Date: 17/02/2026.

To	Opinion							
	Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
Principal, Sri Vidya Kendra (R) The Sruast School # 79/2, Machohalli Beguram P.O. Magadi Road Bengaluru	U882	Ro water	NIL	—	—	SPP	—	—
<p>Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found</p>								

[Signature]
For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Bengaluru

(PTO)

Office of Joint Director

Advice: 1. Sample

Bengaluru - 560001

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

PUBLIC HEALTH INSTITUTE

Bengaluru

(P.T.O)