

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 03-03-2026

It is certified that an inspection team headed by Dr. GANESH G SUVARNA from MEDICAL OFFICER and PHED inspected the THE SMART SCHOOL, 77/2, MACHOHALLI, BAPAGRAM POST, DASANAPURA HOBLI, BANGALORE -560091 on 02-03-2026 and on the basis of Water Test Report (Attached) bearing no. PHI/Water/BAC/1494/2025-26 dated 17-02-2026 and PHC Machohalli lab on 02-03-2026 certified that THE SMART SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State/Central Govt.

This certificate is valid till 02-03-2028

Signature With Seal

Name

: Dr. GANESH G SUVARNA

Designation

: Medical Officer

Name & Address of the Office / Department:

ವೈದ್ಯಾಧಿಕಾರಿಗಳು
ಪ್ರಾ.ಆ. ಕ್ರೇಂದ್ರ - ಮಾಚೋಹಳ್ಳಿ
ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ.

To

THE SMART SCHOOL, 77/2, MACHOHALLI,
BAPAGRAM POST, DASANAPURA HOBLI,
BANGALORE -560091

Principal
THE SMART SCHOOL
77/2, Machohalli,
Bapagram P.O., Magadi Road,
BANGALORE-560 091.

For SRI VIDYA KENDRA

Chairman

Address:

1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

Principal
THE SMART SCHOOL
7712, Machohalli,
Bapagram P.O., Magadi Road,
BANGALORE-560 091

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

SRIVIDYA KENDRA
Srividya
Chairman